



OPTIONAL ANNUAL REPORT TEMPLATE

<b>Drinking-Water System Number:</b>	260086541
<b>Drinking-Water System Name:</b>	YMCA Sudbury - John Island Camp – Shower House
<b>Drinking-Water System Owner:</b>	YMCA Sudbury
<b>Drinking-Water System Category:</b>	Small Non-Municipal, Non-Residential, Seasonal, Serving A Designated Facility
<b>Period being reported:</b>	January 1, 2012 to December 31, 2012

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [X ]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [ X ] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; height: 100px; width: 100%;"></div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served: <input style="width: 50px; text-align: center;" type="text" value="1"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ X ] No [ ]</p> <p>Number of Interested Authorities you report to: <input style="width: 50px; text-align: center;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ X ]</p>
--	---

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?  
 Yes [ ] No [ ]



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method \_\_\_\_\_

**Describe your Drinking-Water System**

A drinking water system serving a designated facility - YMCA John Island Camp, a residential children’s camp operating from May to October in the Township of the North Shore, Ontario. System uses UV treatment as primary disinfection and chlorine as the secondary disinfection. System also employs filtration prior to disinfection.

**List all water treatment chemicals used over this reporting period**

Chlorine

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

Filters, UV bulbs and lights, sample testing – approximate value \$1,500

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date



**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	3	ND - ND	ND- 5	0	N/A
Treated	3	ND – ND	ND – ND	3	ND - 10
Distribution	3	ND - ND	ND - ND	3	ND - ND

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	56	0.09 – .21
Chlorine	56	0.92 – 1.58
Fluoride (If the DWS provides fluoridation)	N/A	

*NOTE: For continuous monitors use 8760 as the number of samples.*

*NOTE: Record the unit of measure if it is not milligrams per litre.*

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	May 6 2009	<0.001	ug/L	
Arsenic	May 6 2009	<1	ug/L	
Barium	May 6 2009	7.9	ug/L	
Boron	May 6 2009	13	ug/L	
Cadmium	May 6 2009	.26	ug/L	
Chromium	May 6 2009	<1	ug/L	
*Lead	May 6 2009	<1	ug/L	
Mercury	May 6 2009	<1	ug/L	
Selenium	May 6 2009	<1	ug/L	
Uranium	May 6 2009	<1	ug/L	



<b>Nitrite</b>	June 21 2010	<0.05	mg/L	
<b>Nitrate</b>	June 21 2010	0.43	mg/L	

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

<b>Location Type</b>	<b>Number of Samples</b>	<b>Range of Lead Results (min#) – (max #)</b>	<b>Number of Exceedances</b>
<b>Plumbing</b>			
<b>Distribution</b>			

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

<b>Parameter</b>	<b>Sample Date</b>	<b>Result Value</b>	<b>Unit of Measure</b>	<b>Exceedance</b>
<b>Alachlor</b>	May 6 2009	<0.61	ug/L	
<b>Aldicarb</b>	May 6 2009	<1.3	ug/L	
<b>Aldrin</b>	May 6 2009	<.00043	ug/L	
<b>Dieldrin</b>	May 6 2009	<.0012	ug/L	
<b>Aldrin + Dieldrin</b>	May 6 2009	<.004	ug/L	
<b>Atrazine</b>	May 6 2009	<.61	ug/L	
<b>Atrazine + N-dealkylated metabolites</b>	May 6 2009	<0.9	ug/L	
<b>Azinphos-methyl</b>	May 6 2009	<.46	ug/L	
<b>Bendiocarb</b>	May 6 2009	<2.6	ug/L	
<b>Benzene</b>	May 6 2009	<0.25	ug/L	
<b>Benzo(a)pyrene</b>	May 6 2009	<0.0055	ug/L	
<b>Bromoxynil</b>	May 6 2009	<0.5	ug/L	
<b>Carbaryl</b>	May 6 2009	<2.6	ug/L	
<b>Carbofuran</b>	May 6 2009	<2.6	ug/L	
<b>Carbon Tetrachloride</b>	May 6 2009	<0.25	ug/L	
<b>Chlordane (Total)</b>	May 6 2009	<0.004	ug/L	
<b>Chlorpyrifos</b>	May 6 2009	<0.46	ug/L	
<b>Cyanazine</b>	May 6 2009	<0.46	ug/L	
<b>Diazinon</b>	May 6 2009	<0.46	ug/L	
<b>Dicamba</b>	May 6 2009	<.2	ug/L	
<b>1,2-Dichlorobenzene</b>	May 6 2009	<0.25	ug/L	
<b>1,4-Dichlorobenzene</b>	May 6 2009	<0.25	ug/L	
<b>Dichlorodiphenyltrichloroethane (DDT) + metabolites</b>	May 6 2009	<0.005	ug/L	



1,2-Dichloroethane	May 6 2009	<0.25	ug/L	
1,1-Dichloroethylene (vinylidene chloride)	May 6 2009	<0.25	ug/L	
Dichloromethane	May 6 2009	<0.25	ug/L	
2-4 Dichlorophenol	May 6 2009	<0.069	ug/L	
2,4-Dichlorophenoxy acetic acid (2,4-D)	May 6 2009	<0.2	ug/L	
Diclofop-methyl	May 6 2009	<0.2	ug/L	
Dimethoate	May 6 2009	<.46	ug/L	
Dinoseb	May 6 2009	<0.05	ug/L	
Diquat	May 6 2009	<7	ug/L	
Diuron	May 6 2009	<13	ug/L	
Glyphosate	May 6 2009	<20	ug/L	
Heptachlor + Heptachlor Epoxide	May 6 2009	<0.00058	ug/L	
Lindane (Total)	May 6 2009	<0.00043	ug/L	
Malathion	May 6 2009	<.46	ug/L	
Methoxychlor	May 6 2009	<0.0012	ug/L	
Metolachlor	May 6 2009	<0.3	ug/L	
Metribuzin	May 6 2009	<0.3	ug/L	
Monochlorobenzene	May 6 2009	<0.25	ug/L	
Paraquat	May 6 2009	<1	ug/L	
Parathion	May 6 2009	<0.3	ug/L	
Pentachlorophenol	May 6 2009	<0.069	ug/L	
Phorate	May 6 2009	<0.46	ug/L	
Picloram	May 6 2009	<.05	ug/L	
Polychlorinated Biphenyls(PCB)	May 6 2009	<0.0066	ug/L	
Prometryne	May 6 2009	<0.3	ug/L	
Simazine	May 6 2009	<0.46	ug/L	
Temephos	May 6 2009	<37	ug/L	
Terbufos	May 6 2009	<0.3	ug/L	
Tetrachloroethylene	May 6 2009	<0.25	ug/L	
2,3,4,6-Tetrachlorophenol	May 6 2009	<0.069	ug/L	
Triallate	May 6 2009	<0.3	ug/L	
Trichloroethylene	May 6 2009	<0.25	ug/L	
2,4,6-Trichlorophenol	May 6 2009	<0.069	ug/L	
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	May 6 2009	<0.05	ug/L	
Trifluralin	May 6 2009	<0.3	ug/L	
Vinyl Chloride	May 6 2009	<0.25	ug/L	
4,4'-DDD	May 6 2009	<.00087	ug/L	
4,4'-DDE	May 6 2009	<.00029	ug/L	
4,4'-DDT	May 6 2009	<.00043	ug/L	
o,p-DDT	May 6 2009	<.00029	ug/L	
Oxychlodane	May 6 2009	<.00072	ug/L	
a-Chlordane	May 6 2009	<.00043	ug/L	
y-Chlordane	May 6 2009	<.00058	ug/L	



<b>Desethyl Atrazine</b>	May 6 2009	<0.76	ug/L	
--------------------------	------------	-------	------	--

**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

<b>Parameter</b>	<b>Result Value</b>	<b>Unit of Measure</b>	<b>Date of Sample</b>
<b>Nitrate</b>	<b>.43</b>	<b>mg/L</b>	<b>June 21, 2010</b>
<b>Barium</b>	<b>7.9</b>	<b>ug/L</b>	<b>May 6 2009</b>
<b>Boron</b>	<b>13</b>	<b>ug/L</b>	<b>May 6 2009</b>
<b>Cadmium</b>	<b>.26</b>	<b>ug/L</b>	<b>May 6 2009</b>