



### CERTIFICATE OF ANALYSIS

Client:	Roxy Peterson	Work Order Number:	347031
Company:	YMCA - John Island Camp - 260041054	PO #:	000275
Address:	140 Durham Street Sudbury, ON, P3E 3M7	Regulation:	O.Reg. 170
Phone:	(902) 300-3812	Project #:	
Email:	roxye33pr@gmail.com	Fax:	
Sampled By:	Eliot Gordon	DWS #:	260041054

Date Order Received:	6/18/2018	Analysis Started:	6/18/2018
Arrival Temperature:	14°C	Analysis Completed:	6/20/2018

### TEST RESULTS

Sample Description	Lab ID	Type / Matrix	Date / Time Collected	Field Chlorine		EC	TC	HPC
				Free	Total			
Treatment Room	1352463	Treated / Water	6/18/2018 6:55 AM			0	0	<10
Kitchen Tap	1352464	Distribution / Water	6/18/2018 6:55 AM			0	0	<10
Treatment Room	1352465	Raw / Water	6/18/2018 6:55 AM			NDOGT	NDOGT	NDOGH PC
Treatment Room	1352465r	Raw / Water	6/18/2018 6:55 AM			NDOGT	NDOGT	NDOGH PC

Result Units: CFU/100mL (water matrix) CFU/g (soil matrix), except HPC which is CFU/1mL. Temp. is in Degrees Celsius.

Note that all tests have been performed in accordance with our accredited and licensed test methods (Method Reference A10 for E. coli, fecal, total coliform and background, and Method Reference A68 for HPC).

### REPORT COMMENTS

Lot#1711

This report has been approved by:

Khaled Omari, Ph.D.  
Laboratory Director

### LEGEND

TESTS EC - Escherichia coli, TC - Total Coliforms, FC - Fecal Coliforms, Back - Background, HPC - Heterotrophic Plate Count

RESULTS ~ - No Data. Results Pending.  
 INT - Interferences are evident on plate and therefore bacterial colonies cannot be properly counted (interferences can be anything that inhibit the proper growth and formation of target colonies)  
 NDOGN - No Data, Overgrown with Non-Target  
 NDOGT - No Data, Overgrown with Target  
 NDOGHPC - No Data, Overgrown with HPC  
 An 'r' after the Lab ID indicates a laboratory replicate.  
 Results relate only to the items tested.